

Varna Drinking Water System

Waterworks # 260019630
System Category – Small Municipal Residential

Annual Drinking Water Report

Prepared For: The Municipality of Bluewater

Reporting Period of January 1 – December 31, 2024

Issued: February 11, 2025

Revision: 0

Operating Authority:



Table of Contents

| | |
|--|----------|
| Annual Drinking Water Report | 1 |
| Table of Contents..... | 1 |
| Overview..... | 1 |
| Report Availability..... | 1 |
| System Process Description..... | 1 |
| Treatment Chemicals used during the reporting year | 1 |
| Summary of Non-Compliance..... | 2 |
| Adverse Water Quality Incidents..... | 2 |
| Non-Compliance | 2 |
| Non-Compliance Identified in a Ministry Inspection..... | 3 |
| Flows..... | 4 |
| Raw and Treated Water Flows | 4 |
| Regulatory Sample Results Summary | 5 |
| Microbiological Testing..... | 5 |
| Operational Testing | 5 |
| Inorganic Parameters | 6 |
| Schedule 15.1 Sampling | 7 |
| Organic Parameters..... | 7 |
| Additional Legislated Samples..... | 8 |
| Major Maintenance and Capital Summary | 9 |
| Revision History..... | 9 |
| Permit to Take Water (PTTW) Data | A |

Overview

This report fulfills requirements of Ontario Regulation 170/03 Section 11 and Schedule 22. The report must be made available to anyone that requests a copy of the report. By March 31, 2025 the report must be provided to members of municipal council.

Report Availability

This system does not serve more than 10 000 residences and the annual reports will be available to residents at the Municipal Office as well as on the municipal website. Notification will be at the Municipal Office and copies provided free of charge if requested. The Municipal Office is located at 14 Mill Ave, Zurich, Ontario, N0M 2T0.

System Process Description

The Varna Drinking Water System serves the community of Varna located in the Municipality of Bluewater; approximate population served is 154.

Water is sourced from a 73 m deep well. The well has a 15.2 cm diameter casing installed to a depth of 57.3 m and extends above grade approximately 33 cm. A 100 mm diameter sleeve is installed from 57.3 m to 73 m and is equipped with a 1.6 L/s submersible pump. The well pump was installed at a depth of 65.8 m with 32 mm diameter galvanized steel discharge piping.

There are three 450 L chlorine contact tanks in the pump house to achieve primary and secondary disinfection requirements. A 12 kW standby propane generator provides backup power to the system. Other equipment includes: three pressure tanks, a 60 L chlorine storage tank, two chlorine pumps, and various other pressure gauges, meters, and sample taps.

The normal operating pressure in the system is set by the pressure switch in the well house to be between 275 and 415 kPa; typical operating pressures in this system are in the range of 250 to 400 kPa.

A 50 mm diameter watermain is installed throughout the distribution system. There are no fire hydrants on the Varna Drinking Water System, however, there is a connection for emergency supply and multiple blow-offs for flushing.

Treatment Chemicals used during the reporting year

Sodium Hypochlorite 12% is used to achieve primary disinfection in the Varna Drinking Water System. Refer to Table 1 below for supplier information.

Table 1: Treatment Chemicals in the Varna Drinking Water System

| Chemical Name | Use | Supplier |
|-------------------------|-------------------|--------------------------|
| Sodium Hypochlorite 12% | Primary Treatment | Jutzi Water Technologies |

Summary of Non-Compliance

Adverse Water Quality Incidents

Under the *Safe Drinking Water Act*, O. Reg 170/03, any adverse water quality incidents (AWQI) are required to be reported to the Ministry of the Environment, Conservation and Parks (MECP) and corrective action taken. Refer to Table 2 below for a summary of AWQI incidents in 2024.

Table 2: *Adverse Water Quality Incidents*

| Date | AWQI # | Location | Problem | Details | Legislation | Corrective Action Taken |
|----------------|--------|--------------|---|---|---------------|--|
| April 28, 2024 | 164895 | Distribution | Loss of pressure and free chlorine residual that didn't meet primary disinfection | Back-up generator failed during power failure | O. Reg 170/03 | Resampled April 28 and April 30 (well house and distribution). All samples met regulatory requirements. Boil Water Advisory issued by Health Unit – lifted May 1. Generator repaired; system flushed to restore primary disinfection. |

Non-Compliance

Under the *Safe Drinking Water Act*, O. Reg 170/03, any events where legislative requirements were not met are required to be reported to the MECP and corrective actions taken. Refer to Table 3 below for a summary of non-compliance incidents in 2024.

Table 3: *Summary of Non-Compliance Incidents*

| Legislation | Requirement(s) system failed to meet | Duration of the failure (ie. Dates(s)) | Corrective Action |
|--------------------------------|---|--|--|
| O. Reg 170/03, Section 6-5 (3) | Continuous monitoring test results must be examined within 72 hours after tests are conducted. Results were not monitored in this time frame due to operator error related to illness. | January 29, 2024, 08:54 – February 1, 2024, 11:09. | A discussion was held with Operators about the importance and requirement of the 72-hour trending review and to obtain back up from another operator if they are unable to fulfill their duties. |
| O. Reg 170/03, Section 6-5 (1) | Continuous monitoring of free chlorine residual must be tested and recorded at a minimum frequency of five minutes. This did not occur due to a power failure and subsequent UPS failure. | May 27, 2024, 06:36 - 07:35 | Upon arrival to the Varna well house at 07:35, an Operator obtained free chlorine grab samples every five minutes until the power returned at 07:47. A new UPS was installed shortly thereafter. |
| O. Reg 170/03, Section 6-5 (1) | Continuous monitoring of free chlorine residual must be tested and | September 30, 2024, 16:24 - October 1, 2024, 10:01 | On October 1, 2024, at 10:01, the issue was resolved by tightening a |

| | | | |
|--|--|--|--|
| | <p>recorded at a minimum frequency of five minutes. This did not occur due to a loose wire on the analyzer’s chlorine probe which caused a faulty reading on the analyzer.</p> | | <p>loose wire on the chlorine probe which caused the analyzer error.</p> |
|--|--|--|--|

Non-Compliance Identified in a Ministry Inspection

MECP inspections occur within an April 1 to March 31 fiscal year. The last inspection occurred in 2023 and there were no MECP inspections in 2024, therefore no non-compliances identified.

Flows


Raw and Treated Water Flows

The raw and treated water flows are regulated under the Permit to Take Water (PTTW #0266-AE9NRG) and Municipal Drinking Water Licence (MDWL #045-106). The 2024 daily raw flow was submitted to the Ministry electronically under the PTTW number. A copy of the data that was submitted is attached in Appendix A.

The total volume of treated water in 2024 was 10 136 m³. In 2023, the total volume was 10 417 m³.


The Varna DWS pumps water from its onsite well where the flow is measured. This flow measures the raw water for the PTTW and the treated water for the rated capacity for the MDWL. Both of these (PTTW and MDWL) limit the flow to 144 m³/d. The average daily flow in 2024 was 28 m³ compared to 29 m³ in 2023 (Figure 1). The system is currently operating at 19% of its rated capacity.

Figure 1: Average Daily Flows



The maximum daily flow in 2024 was 74 m³/d compared to 63 m³/d in 2023 (Figure 2). The limit for water taking as per the PTTW is 100 L/min or 144 m³/d. This limit was not exceeded in 2024.

Figure 2: Maximum Daily Flow



Regulatory Sample Results Summary

Microbiological Testing

To meet regulatory requirements, raw water (RW) is sampled monthly and distribution water (DW) weekly to test for E. coli, Total Coliforms and heterotrophic plate count (HPC). The regulatory limit for Total Coliform and E. coli is zero, heterotrophic plate count (HPC) doesn't have a limit. Additional treated water samples were taken for monitoring purposes. Refer to Table 4 below for a summary of testing results.

Table 4: Microbiological Testing Summary

| | No. of Samples Collected | Range of E.Coli Results (cfu/100mL) | | Range of Total Coliform Results | | No. of HPC Samples Collected | Range of HPC Results (cfu/mL) | |
|--------------------|--------------------------|-------------------------------------|-----|---------------------------------|-----|------------------------------|-------------------------------|-----|
| | | Min | Max | Min | Max | | Min | Max |
| Raw Water | 12 | 0 | 0 | 0 | 0 | n/a | n/a | n/a |
| Treated Water | 3 | 0 | 0 | 0 | 0 | n/a | n/a | n/a |
| Distribution Water | 55 | 0 | 0 | 0 | 0 | 55 | 10 | 60 |

Operational Testing

As per the *Safe Drinking Water Act*, O. Reg 170/03, raw water turbidity is required to be monitored monthly with an objective of turbidity less than 1 NTU. Free chlorine residuals are required to be continuously monitored with an online chlorine analyzer. Free chlorine residuals are also monitored throughout the distribution system to ensure adequate secondary disinfection is provided. The

regulatory requirement for free chlorine residual is a minimum of 0.05 mg/L with an objective of 0.20 mg/L throughout the distribution system. Refer to Table 5 for turbidity and free chlorine residual results.

Table 5: Turbidity and Free Chlorine Residual Monitoring

| Parameter | No. of Samples Collected | Range of Results | |
|---|--------------------------|------------------|---------|
| | | Minimum | Maximum |
| Turbidity, grab (NTU) – RW | 12 | 0.23 | 0.48 |
| Free Chlorine Residual, On-Line (mg/L) - TW | 8760 | 0.0* | 2.02 |
| Free Chlorine Residual, grab (mg/L) - DW | 105 | 0.77 | 1.63 |

*AWQI April 28, 2024 - refer to Table 2 for details.

Inorganic Parameters

Inorganic parameters are tested as a requirement under O. Reg. 170/03 every 60 months, including sodium and fluoride. Nitrate and Nitrite are tested quarterly as required under O. Reg. 170/03. In the event any of the parameters (except Sodium and Fluoride) exceed half of the maximum allowable concentration, the parameter is required to be sampled quarterly. Refer to Table 6 below.

Table 6: Inorganic Parameter Testing

| Treated Water (TW) | Sample Date (yyyy/mm/dd) | Sample Result | MAC | Number of Exceedances | |
|------------------------------|--------------------------|---------------|--------|-----------------------|---------|
| | | | | MAC | 1/2 MAC |
| Antimony: Sb (ug/L) - TW | 2022/11/01 | <MDL 0.6 | 6.0 | 0 | 0 |
| Arsenic: As (ug/L) - TW | 2022/11/01 | 1.5 | 10.0 | 0 | 0 |
| Barium: Ba (ug/L) - TW | 2022/11/01 | 123.0 | 1000.0 | 0 | 0 |
| Boron: B (ug/L) - TW | 2022/11/01 | 69.0 | 5000.0 | 0 | 0 |
| Cadmium: Cd (ug/L) - TW | 2022/11/01 | 0.005 | 5.0 | 0 | 0 |
| Chromium: Cr (ug/L) - TW | 2022/11/01 | <MDL 0.08 | 50.0 | 0 | 0 |
| Mercury: Hg (ug/L) - TW | 2022/11/01 | <MDL 0.01 | 1.0 | 0 | 0 |
| Selenium: Se (ug/L) - TW | 2022/11/01 | 0.11 | 50.0 | 0 | 0 |
| Uranium: U (ug/L) - TW | 2022/11/01 | 1.11 | 20.0 | 0 | 0 |
| Additional Inorganics | | | | | |
| Fluoride (mg/L) - TW | 2022/11/01 | 1.15 | 1.5 | 0 | n/a |
| Nitrite (mg/L) - TW | 2024/01/02 | <MDL 0.003 | 1.0 | 0 | 0 |
| Nitrite (mg/L) - TW | 2024/04/02 | <MDL 0.003 | 1.0 | 0 | 0 |
| Nitrite (mg/L) - TW | 2024/07/02 | <MDL 0.003 | 1.0 | 0 | 0 |
| Nitrite (mg/L) - TW | 2024/10/01 | <MDL 0.003 | 1.0 | 0 | 0 |
| Nitrate (mg/L) - TW | 2024/01/02 | <MDL 0.006 | 10.0 | 0 | 0 |
| Nitrate (mg/L) - TW | 2024/04/02 | <MDL 0.006 | 10.0 | 0 | 0 |
| Nitrate (mg/L) - TW | 2024/07/02 | <MDL 0.006 | 10.0 | 0 | 0 |
| Nitrate (mg/L) - TW | 2024/10/01 | <MDL 0.006 | 10.0 | 0 | 0 |
| Sodium: Na (mg/L) - TW | 2022/11/01 | 10.6 | 20* | n/a | n/a |

MAC = Maximum Allowable Concentration as per O.Reg 169/03

MDL = Below the laboratory method detection level

*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified mg/L when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium-restricted diets.

Schedule 15.1 Sampling:

Schedule 15.1 Sampling is required under O. Reg 170/03. This includes sampling for lead, alkalinity and pH. The Varna Drinking Water System is under reduced sampling. As such, no residential plumbing samples were required to be collected. Monitoring the pH and alkalinity in the distribution system is essential to ensure adequate buffering for corrosion control and to minimize exposure to metals such as lead. Refer to Table 7 below.

Table 7: Schedule 15.1 Sampling Results

| Distribution System | Number of Sampling Points | Number of Samples | Range of Results | | MAC (ug/L) | Number of Exceedances |
|---------------------|---------------------------|-------------------|------------------|---------|------------|-----------------------|
| | | | Minimum | Maximum | | |
| Alkalinity (mg/L) | 2 | 4 | 228 | 269 | n/a | n/a |
| pH | 2 | 4 | 7.02 | 7.45 | n/a | n/a |
| Lead (ug/l) | 2 | 4 | 0.03 | 0.30 | 10 | 0 |

Organic Parameters

Organic parameters are tested every 60 months as a requirement under O. Reg 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly. Organic parameter test results for treated water are listed below in Table 8.

Chlorine byproducts including Trihalomethane and Haloacetic Acid are tested quarterly in the distribution system. Results are listed in Table 8 below.

Table 8: Organic Parameter Testing

| Treated Water (TW) | Sample Date (yyyy/mm/dd) | Sample Result | MAC | Number of Exceedances | |
|--|--------------------------|---------------|-------|-----------------------|---------|
| | | | | MAC | 1/2 MAC |
| Alachlor (ug/L) - TW | 2022/11/01 | <MDL 0.02 | 5.0 | 0 | 0 |
| Atrazine + N-dealkylated metabolites (ug/L) - TW | 2022/11/01 | <MDL 0.01 | 5.0 | 0 | 0 |
| Azinphos-methyl (ug/L) – TW | 2022/11/01 | <MDL 0.05 | 20.0 | 0 | 0 |
| Benzene (ug/L) – TW | 2022/11/01 | <MDL 0.32 | 1.0 | 0 | 0 |
| Benzo(a)pyrene (ug/L) – TW | 2022/11/01 | <MDL 0.004 | 0.01 | 0 | 0 |
| Bromoxynil (ug/L) – TW | 2022/11/01 | <MDL 0.33 | 5.0 | 0 | 0 |
| Carbaryl (ug/L) – TW | 2022/11/01 | <MDL 0.05 | 90.0 | 0 | 0 |
| Carbofuran (ug/L) - TW | 2022/11/01 | <MDL 0.01 | 90.0 | 0 | 0 |
| Carbon Tetrachloride (ug/L) - TW | 2022/11/01 | <MDL 0.17 | 2.0 | 0 | 0 |
| Chlorpyrifos (ug/L) - TW | 2022/11/01 | <MDL 0.02 | 90.0 | 0 | 0 |
| Diazinon (ug/L) – TW | 2022/11/01 | <MDL 0.02 | 20.0 | 0 | 0 |
| Dicamba (ug/L) – TW | 2022/11/01 | <MDL 0.2 | 120.0 | 0 | 0 |
| 1,2-Dichlorobenzene (ug/L) – TW | 2022/11/01 | <MDL 0.41 | 200.0 | 0 | 0 |
| 1,4-Dichlorobenzene (ug/L) – TW | 2022/11/01 | <MDL 0.36 | 5.0 | 0 | 0 |
| 1,2-Dichloroethane (ug/L) – TW | 2022/11/01 | <MDL 0.35 | 5.0 | 0 | 0 |
| 1,1-Dichloroethylene (ug/L) – TW | 2022/11/01 | <MDL 0.33 | 14.0 | 0 | 0 |
| Dichloromethane (ug/L) – TW | 2022/11/01 | <MDL 0.35 | 50.0 | 0 | 0 |
| 2,4-Dichlorophenol (ug/L) – TW | 2022/11/01 | <MDL 0.15 | 900.0 | 0 | 0 |
| 2,4-Dichlorophenoxy acetic acid (ug/L) – TW | 2022/11/01 | <MDL 0.19 | 100.0 | 0 | 0 |
| Diclofop-methyl (ug/L) – TW | 2022/11/01 | <MDL 0.4 | 9.0 | 0 | 0 |

| Treated Water (TW) | Sample Date (yyyy/mm/dd) | Sample Result | MAC | Number of Exceedances | |
|--|-----------------------------|---------------|-------|-----------------------|---------|
| | | | | MAC | 1/2 MAC |
| Dimethoate (ug/L) – TW | 2022/11/01 | <MDL 0.06 | 20.0 | 0 | 0 |
| Diquat (ug/L) – TW | 2022/11/01 | <MDL 1.0 | 70.0 | 0 | 0 |
| Diuron (ug/L) – TW | 2022/11/01 | <MDL 0.03 | 150.0 | 0 | 0 |
| Glyphosate (ug/L) – TW | 2022/11/01 | <MDL 1.0 | 280.0 | 0 | 0 |
| Malathion (ug/L) – TW | 2022/11/01 | <MDL 0.02 | 190.0 | 0 | 0 |
| 2-Methyl-4chlorophenoxyacetic Acid (MCPA) | 2022/11/01 | <MDL 0.01 | 50.0 | 0 | 0 |
| Metolachlor (ug/L) – TW | 2022/11/01 | <MDL 0.02 | 80.0 | 0 | 0 |
| Metribuzin (ug/L) – TW | 2022/11/01 | <MDL 0.3 | 80.0 | 0 | 0 |
| Monochlorobenzene (Chlorobenzene) (ug/L) - | 2022/11/01 | <MDL 1.0 | 10.0 | 0 | 0 |
| Paraquat (ug/L) – TW | 2022/11/01 | <MDL 0.04 | 3.0 | 0 | 0 |
| PCB (ug/L) – TW | 2022/11/01 | <MDL 0.15 | 60.0 | 0 | 0 |
| Pentachlorophenol (ug/L) – TW | 2022/11/01 | <MDL 0.01 | 2.0 | 0 | 0 |
| Phorate (ug/L) – TW | 2022/11/01 | <MDL 1.0 | 190.0 | 0 | 0 |
| Picloram (ug/L) – TW | 2022/11/01 | <MDL 0.03 | 1.0 | 0 | 0 |
| Prometryne (ug/L) – TW | 2022/11/01 | <MDL 0.01 | 10.0 | 0 | 0 |
| Simazine (ug/L) – TW | 2022/11/01 | <MDL 0.01 | 1.0 | 0 | 0 |
| Terbufos (ug/L) – TW | 2022/11/01 | <MDL 0.35 | 10.0 | 0 | 0 |
| Tetrachloroethylene (ug/L) – TW | 2022/11/01 | <MDL 0.2 | 100.0 | 0 | 0 |
| 2,3,4,6-Tetrachlorophenol (ug/L) – TW | 2022/11/01 | <MDL 0.01 | 230.0 | 0 | 0 |
| Triallate (ug/L) - TW | 2022/11/01 | <MDL 0.44 | 5.0 | 0 | 0 |
| Trichloroethylene (ug/L) – TW | 2022/11/01 | <MDL 0.25 | 5.0 | 0 | 0 |
| 2,4,6-Trichlorophenol (ug/L) – TW | 2022/11/01 | <MDL 0.12 | 100.0 | 0 | 0 |
| Trifluralin (ug/L) – TW | 2022/11/01 | <MDL 0.02 | 45.0 | 0 | 0 |
| Vinyl Chloride (ug/L) – TW | 2022/11/01 | <MDL 0.17 | 1.0 | 0 | 0 |
| Distribution Water | | | | | |
| Trihalomethane: Total (ug/L) Annual Average | 2024 | 2.23 | 100.0 | 0 | 0 |
| Haloacetic Acid: Total (ug/L) Annual Average | 2024 | 5.3 | 80.0 | 0 | 0 |

MAC = Maximum Allowable Concentration as per O. Reg 169/03

MDL = Below the laboratory method detection level

Additional Legislated Samples

There are no additional sampling requirements within the Varna Drinking Water System.

Major Maintenance and Capital Summary

The Varna Drinking Water System completed repairs and replacements as listed below in Table 9. These represent the major expenses incurred in 2024.

Table 9: *Major Maintenance*

| Item | Description |
|------|--|
| 1 | Pipe Repair – Varna Well House |
| 2 | Sump Pump and Sump Pump Float Replacement |
| 3 | Chlorine Injectors, Pump 1 and 2 Replacement |
| 4 | Generator Repaired |
| 5 | UPS Replacement |

Revision History

| Date | Revision # | Revision |
|-------------------|------------|---------------|
| February 11, 2025 | 0 | Issued Report |

Appendix A

Permit to Take Water (PTTW) Data

**Ontario Clean Water Agency
Annual Water Taking and Transfer Report**

From 1/1/2024 To 12/31/2024
VARNA DRINKING WATER SYSTEM - 1388

PTTW # 0266-AE9NRG

Flow Recorded in L/d

| Date | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 1 | 20507.9994 | 17531.9996 | 17951.0002 | 22002.0008 | 21903.9993 | 33874.0009 | 28021.9994 | 27222.9996 | 30238.0009 | 32116.0011 | 30415.0009 | 36105.9990 |
| 2 | 20923.9998 | 18059.9995 | 19687.0003 | 18080.9994 | 23201.9997 | 30345.9995 | 26049.9992 | 22218.9999 | 32384.9983 | 29365.9992 | 32431.9992 | 34744.9989 |
| 3 | 19346.0007 | 19207.0007 | 20183.0006 | 19791.0004 | 19882.0000 | 26023.0007 | 27290.0009 | 23139.9994 | 31635.0002 | 32362.9990 | 34622.0016 | 34839.0007 |
| 4 | 17492.0006 | 21263.9999 | 18916.0004 | 19295.0001 | 32794.9995 | 32304.0009 | 27531.0001 | 23563.0002 | 29038.0001 | 28020.0005 | 33028.9993 | 37519.0010 |
| 5 | 17007.9994 | 18357.9998 | 18207.0007 | 18194.0002 | 32722.9996 | 28966.9991 | 20920.0001 | 24311.0008 | 31051.0006 | 35292.9993 | 34273.9983 | 37995.9984 |
| 6 | 18856.0009 | 18875.0000 | 22447.0005 | 17916.0004 | 19875.0000 | 27475.9998 | 39153.9993 | 20729.0001 | 27337.9993 | 29396.9994 | 39013.9999 | 36882.9994 |
| 7 | 19899.9996 | 21662.0007 | 19079.9999 | 23607.9998 | 20188.9992 | 27194.9997 | 74491.9968 | 20853.0006 | 29149.9996 | 31340.0002 | 34587.0018 | 37466.9991 |
| 8 | 19361.9995 | 18666.0004 | 19965.0002 | 20709.9991 | 21111.9995 | 24718.9999 | 42169.9982 | 21882.9994 | 28895.9994 | 37900.0015 | 37467.9985 | 38277.0004 |
| 9 | 20093.9999 | 23236.9995 | 22357.0004 | 18198.9994 | 21187.9997 | 27527.0004 | 30260.9997 | 24823.0000 | 30337.9993 | 30472.9996 | 35263.9999 | 36882.9994 |
| 10 | 17600.0004 | 19051.0006 | 22374.0005 | 19104.9995 | 22337.9993 | 28309.0008 | 21187.9997 | 23201.9997 | 34182.9987 | 32909.9998 | 36379.0016 | 34598.9990 |
| 11 | 16985.0006 | 23076.0002 | 20190.0005 | 17590.0002 | 22667.9993 | 29327.9991 | 25256.0005 | 25263.9999 | 35049.9992 | 29659.0004 | 34248.0011 | 35209.9991 |
| 12 | 18474.0009 | 18700.0008 | 29523.0007 | 19382.0000 | 23600.0004 | 33033.0009 | 34105.9990 | 29805.0003 | 31649.0002 | 32118.0000 | 33455.0018 | 36354.9995 |
| 13 | 20974.0009 | 20170.9995 | 20597.0001 | 21003.0003 | 21823.9994 | 32527.0004 | 42902.9999 | 22062.0003 | 30958.0002 | 31580.9994 | 32874.0005 | 33840.9996 |
| 14 | 21864.9998 | 19700.0008 | 19572.0005 | 23545.9995 | 21399.9996 | 36670.0007 | 28853.0006 | 22462.9993 | 30326.0002 | 34013.9999 | 34165.0009 | 35033.0009 |
| 15 | 19568.0008 | 16944.0002 | 18725.0004 | 19600.9998 | 22659.0004 | 60612.0008 | 21444.9997 | 26336.9999 | 38623.0011 | 33055.0003 | 32437.0003 | 36544.9982 |
| 16 | 21954.0005 | 18763.9999 | 17486.9995 | 19270.9999 | 21555.0003 | 59141.9983 | 22857.9998 | 21736.9995 | 31604.0001 | 32523.9983 | 35757.0000 | 39083.0002 |
| 17 | 19916.0004 | 18787.0007 | 21780.0007 | 19284.0004 | 23226.9993 | 48909.0004 | 22962.9993 | 21906.0001 | 29895.0005 | 32556.9992 | 40056.9992 | 36911.9987 |
| 18 | 17569.9997 | 23541.9998 | 18863.0009 | 19408.0009 | 24587.9993 | 59176.9981 | 25490.9992 | 21073.0000 | 32165.0009 | 29858.9993 | 34562.0003 | 35347.0001 |
| 19 | 16884.0008 | 22899.9996 | 19864.9998 | 18839.0007 | 29288.0001 | 36462.0000 | 22198.0000 | 21615.9992 | 34293.9987 | 34528.9993 | 35737.9990 | 34244.9989 |
| 20 | 20065.0005 | 19285.9993 | 19084.9991 | 25086.9999 | 38113.9992 | 33203.9986 | 29427.9995 | 26087.9993 | 30597.9996 | 33847.9996 | 34823.0019 | 34162.9982 |
| 21 | 20746.0003 | 19604.9995 | 33402.9999 | 21875.0000 | 27123.9993 | 35946.0013 | 42313.9992 | 23687.9997 | 38915.0009 | 32830.0018 | 42876.9989 | 39985.0006 |
| 22 | 17319.0002 | 21184.0000 | 19202.9991 | 19944.0002 | 28489.0003 | 36518.0016 | 25349.0009 | 28002.0008 | 31896.9994 | 31992.0006 | 34560.0014 | 39888.9999 |
| 23 | 25459.9991 | 18846.0007 | 19645.9999 | 24447.0005 | 30339.0007 | 32602.0012 | 28565.0005 | 31590.9996 | 29538.0001 | 29142.9996 | 36581.0013 | 35449.0013 |
| 24 | 20405.0007 | 20681.9992 | 21704.0005 | 27368.9995 | 32074.0013 | 27040.0009 | 26000.0000 | 31788.0001 | 32259.9983 | 29370.0008 | 37985.0006 | 38001.9989 |
| 25 | 18613.0009 | 22382.9994 | 19309.9995 | 18216.9991 | 27219.9993 | 19406.9996 | 25955.9994 | 37701.9997 | 33613.9984 | 28163.9996 | 34271.9994 | 34363.9984 |
| 26 | 16760.9997 | 18665.0009 | 20669.0006 | 20104.0001 | 40229.0001 | 21146.9994 | 24042.9993 | 39209.9991 | 32040.0009 | 32025.0015 | 37854.9995 | 34828.9986 |
| 27 | 17749.0005 | 17725.0004 | 20659.0004 | 29945.0005 | 26666.0004 | 21632.0000 | 27108.9993 | 30684.9995 | 30024.0002 | 34376.9989 | 36098.9990 | 34008.9989 |
| 28 | 21916.9998 | 19354.9995 | 17069.9997 | 32381.9998 | 32555.9998 | 26066.0000 | 38870.9984 | 26343.0004 | 31166.0004 | 30014.9994 | 36271.9994 | 34731.9984 |
| 29 | 19193.0008 | 20528.9993 | 19593.0007 | 23358.9993 | 33804.0009 | 21655.0007 | 25330.9994 | 30520.9999 | 35236.9995 | 33269.0010 | 36219.0018 | 42694.0002 |
| 30 | 17885.0002 | | 18645.9999 | 23424.9992 | 32250.9995 | 23802.9995 | 20997.9992 | 29371.0003 | 31270.9999 | 34098.9990 | 37865.0017 | 37213.0013 |
| 31 | 18534.0004 | | 19466.9991 | | 31027.9999 | | 27158.0009 | 28291.9998 | | 32134.9983 | | 37402.0004 |